

GUIDELINES FOR SWIMMING POOL DISCHARGE SUBMITTALS TO THE DEPARTMENT OF ENVIRONMENTAL PROTECTION

1. Submission has to be by a Professional Engineer or Registered Architect in the State of New York (original of license stamp/seal and signature to appear on letter as well as on the plans).
2. Plans should be to scale with scales indicated.
3. Block, Lot, House number, and the name of the street should be shown in the letter as well as on the plans.
4. Existing sewer size and type in street should also be indicated on the Site plan. Indicate distance between building lines and sewer.
5. For house sewer connections indicate:
 - a. Size (inside diameter in inches)
 - b. Type (sanitary or combined)
6. North Arrow should be shown.
7. As-Built Sewer Plans should be submitted.
8. Evidence of existing house sewer connection should be submitted.
9. Indicate capacity of swimming pool in gallons in the letter as well as on the plans and its hydraulic calculations.
10. Exact conditions of discharge of the pool to the internal sanitary system should be indicated, i.e. time at night in dry weather, duration, maximum flow, etc.